

DIRECTIONS FOR READING RECTIFIER

In order that optimum operation of the underground corrosion control system be maintained, please record the rectifier data and mail or fax it to "ASM Corrosion Control Ltd." on a monthly basis. The instructions for this are as follows:

1. Facility Name: _____

Address: _____

2. Date: _____

3. Read by: _____

4. Rectifier Data:

a. Is the rectifier On/Off Switch ON YES _____ NO _____

If it is "OFF" turn it "ON"

Does it stay "ON"? YES _____ NO _____

b. Does the unit look O.K.? YES _____ NO _____

If not, describe the problem on the back of this page.

3. If there are separate voltage and amperage meters, what are they reading?

Volts _____	Total Amps _____	CC#1 Amps _____	CC#2 Amps _____
-------------	---------------------	--------------------	--------------------

NOTE: If there is only one meter and there are voltage and amperage scales on the meter, there will be a selector switch somewhere on the panel. Push the switch in the direction marked "Amps" and read the meter using the amperage scale. Then push the switch in the other direction marked "Volts" and read the meter using the voltage scale.

4. Submit this form to: ASM CORROSION CONTROL LTD.
#2, 10016 - 29A Avenue
Edmonton, Alberta
T6N 1A8

Attention: Mr. S.A. Larocque, C.E.T.
Manager

Telephone: (780) 461-4799
Fax: (780) 461-6067